

*Current Concepts***BUILDING-RELATED ILLNESSES**

DICK MENZIES, M.D., AND JEAN BOURBEAU, M.D.

OVER the past 30 years, a new man-made ecosystem has developed — the controlled indoor environment within the sealed exterior shells of modern office buildings. This new environment has considerable potential to affect public health because more than half the adult work force in North America and Western Europe works in offices or “office-like” nonindustrial environments.¹ The indoor environment of modern office buildings may be affected by the occupants, their work activities, equipment, plants, furnishings, building materials, ventilation systems, and outdoor air pollution. In the vast majority of buildings, this complex environment is controlled by one or two technicians who monitor the highly automated heating, ventilation, and air-conditioning systems. These technicians have no way to measure indoor air-pollution levels and little direct contact with the building’s occupants.

In the past two decades a group of health problems related to this ecosystem — termed building-related illnesses — has emerged. In this review we attempt to provide advice to health professionals who are evaluating workers with health problems that may be related to this work environment. The evidence cited has been restricted to descriptions of outbreaks in which a causative agent could be identified, population-based studies of office workers, and experimental manipulations of exposure to substances present in the office environment.

DEFINITIONS

In this review, the term “building-related illness” will be used for illnesses that arise in nonindustrial, nonresidential buildings, of which the majority are office buildings. The term “specific building-related illnesses” refers to a group of illnesses with a fairly homogeneous clinical picture, objective abnormalities on clinical or laboratory evaluation, and one or more identifiable sources or agents known to cause infectious, immunologic, or allergic diseases. “Non-

specific building-related illnesses” will be used to refer to a heterogeneous group of work-related symptoms — including irritation of the skin and mucous membranes of the eyes, nose, and throat, headache, fatigue, and difficulty concentrating. These are considered illnesses on the basis of the occurrence of symptoms, even though affected workers do not have objective clinical or laboratory abnormalities and causative agents cannot be found. The symptoms may be considered building-related even if the only supportive evidence is workers’ reports. We avoid the term “sick building syndrome,”² since it suggests that buildings require investigation and treatment, whereas physicians are confronted with individual workers with potentially work-related health problems. The term is also inaccurate in suggesting that there are two populations of buildings — sick and healthy; this conclusion is not supported by epidemiologic surveys of workers in many buildings.³⁻¹² Moreover, the designation of “healthy buildings” may be harmful because it suggests that in such buildings, the symptoms of affected workers can be presumed to be unrelated to the work environment.

SPECIFIC BUILDING-RELATED ILLNESSES

Table 1 summarizes the chief specific building-related illnesses. Transmission of certain respiratory pathogens¹⁶⁻¹⁸ may be increased by crowding or a reduced outdoor-air exchange rate. A single causative agent may result in building-related outbreaks with very different manifestations. For example, *Legionella pneumophila* can result in legionnaires’ disease, a pneumonia with a case fatality rate of 10 to 15 percent,^{13,15} or Pontiac fever, a milder, flulike illness.^{14,15} Similarly, hypersensitivity pneumonitis and humidifier fever were originally described as separate disorders but may coexist and result from similar immunologic responses to fungi, bacteria, or protozoa contaminating humidifiers or ventilation systems.¹⁹⁻²² Manifestations of both disorders include fever, chills, malaise, and the presence of specific antibodies to the microbial agent. Hypersensitivity pneumonitis has additional features of cough, chest tightness, dyspnea, lung-function abnormalities, and occasionally, radiographic abnormalities. When all exposed workers have been carefully examined, there is a wide spectrum of manifestations.²⁰⁻²² For example, in one group of 14 workers exposed to levels of penicillium of 5000 to 10,000 colony-forming units per cubic meter, hypersensitivity pneumonitis developed in 1 nonsmoking worker, asthma developed in another with a history of atopy and cigarette smoking, and 6 others had nonspecific respiratory symptoms.²¹

Outbreaks of asthma related to exposure in office buildings have been reported rarely, although the causative agent in such outbreaks has not been identified.^{23,24} Exposure to common indoor allergens such as dust mites, plant products, and passively

From the Departments of Medicine and Epidemiology and Biostatistics, Montreal Chest Institute, and the Respiratory Epidemiology Unit, McGill University — both in Montreal. Address reprint requests to Dr. Menzies at the Respiratory Epidemiology Unit, McGill University, 1110 Pine Ave. W., Montreal, QC H3A 1A3, Canada.

©1997, Massachusetts Medical Society.

TABLE 1. SPECIFIC ILLNESSES KNOWN OR SUSPECTED TO BE RELATED TO BUILDINGS.*

DISEASE	TYPE OF STUDY	TYPE OF BUILDING	INDOOR SOURCE	AGENT OR EXPOSURE
Infectious				
Legionnaires' disease and Pontiac fever	Case reports (sporadic or epidemic) ¹³⁻¹⁵	Large buildings (offices, hospitals, hotels)	Cooling tower, air conditioning, or humidifier, potable water	<i>Legionella pneumophila</i>
Flulike illness and common cold	Cross-sectional study ¹⁶ Longitudinal study ¹⁷	Office buildings Military barracks	Human source	Respiratory virus
Tuberculosis	Index case followed by cross-sectional study ¹⁸	Office buildings	Human source	<i>Mycobacterium tuberculosis</i>
Immunologic				
Hypersensitivity pneumonitis and humidifier fever	Case reports ¹⁹	Office buildings	Humidifier	Multiple bacteria, fungus, actinomycetes
	Index cases followed by cross-sectional study ²⁰⁻²²	Office buildings, factory	Air conditioning, humidifier, ventilation unit	Aspergillus, penicillium, multiple organisms
Allergic				
Dermatitis, rhinitis, and asthma	Case reports	Office buildings	Surface dust, carpet, clothing	Dust mites, plant products, animal allergens, fungus
	Index cases followed by cross-sectional study ^{23,24}	Office buildings and factory	Humidifier	Unknown
Rhinitis				
Contact urticaria, laryngeal edema	Case reports ²⁵⁻²⁸	Office buildings	Carbonless copy paper	Alkylphenol novolac resin
Irritation				
Dermatitis, upper and lower respiratory tract irritation	Case reports ²⁹⁻³¹	Office buildings	Ceiling boards	Glass fibers
	Case report ³²	Office buildings	Tobacco smoke, vehicle exhaust, any combustion process	Combustion products (e.g., carbon monoxide, nitrogen dioxide)

*Data are from case reports, studies of index cases followed by epidemiologic evaluations, or field studies (when available).

transported allergens may occur in any occupied building. Challenge tests with photocopier fumes have produced hypersensitivity angitis,²⁵ and tests with carbonless copy papers have produced urticaria and laryngeal edema^{26,27} or pharyngitis.²⁸

Dermatitis, conjunctivitis, and upper and lower respiratory tract symptoms may also represent irritant responses due to exposure to nonallergenic agents. Exposure to man-made vitreous fibers has produced itching skin, burning eyes, sore throat, and cough.^{29,30} Glass fibers may be released from ceiling boards through direct physical damage or indirectly through the movement of boards by building vibrations or room-pressure changes when doors are opened or closed.^{29,30}

Carboxyhemoglobin levels of 2.0 to 3.5 percent have been measured in nonsmokers exposed to indoor carbon monoxide concentrations of 4 to 10 ppm. Therefore, exposure to levels of 20 to 50 ppm from heavy cigarette smoking³³ or intake of exhaust fumes³² could result in carboxyhemoglobin concentrations of 5 to 10 percent, which can diminish cognitive function and alertness³⁴ and produce symptoms of headache and dizziness — so-called occult carbon monoxide poisoning.³⁵ Indoor exposure to nitrogen dioxide can occur as a result of the intake of exhaust fumes or from high outdoor levels^{36,37} and can result in mucosal irritation with respiratory

symptoms and an increase in respiratory tract infections. Formaldehyde is well recognized as a mucosal irritant, but there are no well-documented outbreaks of illness related to exposure to this agent in office buildings.³⁸

NONSPECIFIC BUILDING-RELATED ILLNESSES

In cross-sectional surveys in buildings selected without regard to the occupants' health status, up to 60 percent of workers reported at least one work-related symptom, and 10 to 25 percent reported that such symptoms occurred twice weekly or more often.^{6,7,9,11,12,39} The associations of such symptoms with a younger age, female sex, and a history of atopy (Table 2) may reflect heightened physiologic responses at lower thresholds⁴⁶⁻⁴⁹ or greater occupational exposure.⁵⁰ The association of symptoms with psychosocial factors does not mean that "the problem is all in the workers' heads." The results of psychological testing of symptomatic and asymptomatic office workers are similar,⁵¹ psychosocial factors are associated with cardiovascular disease,⁵² and such factors can result from, rather than cause, health problems.⁵³

As reviewed extensively elsewhere,⁵⁴ exposure to environmental tobacco smoke in nonwork environments (primarily the home) has been consistently

TABLE 2. RELATION OF PERSONAL, WORK, WORK-SITE, AND BUILDING-VENTILATION CHARACTERISTICS AND NONSPECIFIC BUILDING-RELATED ILLNESSES AMONG OFFICE WORKERS.

CHARACTERISTIC	STUDIES FINDING AN ASSOCIATION			STUDIES FINDING NO ASSOCIATION		
	NO. OF STUDIES	NO. OF SUBJECTS	REFERENCE	NO. OF STUDIES	NO. OF SUBJECTS	REFERENCE
Personal						
Female sex	7	23,764	3-5, 7, 12, 41, 42	1	3,948	10
Younger age	4	17,166	4, 10, 12, 42	2	8,450	3, 5
Atopy, allergy, asthma	9	23,662	3, 5-7, 10, 12, 40-42	0	—	—
Cigarette smoking						
Active	2	8,433	7, 12	4	13,944	3, 5, 10, 42
Passive	3	15,017	4, 12, 41	2	5,338	7, 10
Psychosocial factors	7	21,762	3, 5, 7, 10, 12, 40, 41	0	—	—
Work						
Clerical work	3	9,301	3, 4, 7	2	6,489	5, 42
Work with video-display terminals	6	22,277	3, 5, 7, 10, 12, 42	1	880	43
Work with carbonless paper	4	16,373	3, 5, 12, 43	0	—	—
Work with or near photocopiers	4	10,720	3, 5, 7, 43	1	3,948	10
Work site						
Open-concept office	2	6,489	5, 42	1	3,948	10
Crowding	3	11,430	3, 12, 43	0	—	—
Presence of carpets	3	8,335	3, 10, 43	1	4,943	5
Surface dust	2	7,455	3, 10	2	11,986	5, 12
Noise	2	5,338	7, 10	0	—	—
Building						
Ventilation						
Simple mechanical	3	8,168	8, 9, 44	2	12,977	6, 11
Air conditioning	5	26,838	8, 9, 11, 12, 44	0	—	—
Humidification	2	9,721	8, 12	1	11,627	11
Ventilation rate <10 liters/sec/person	3	4,959	6, 39, 41	0	—	—

associated with a number of adverse health effects, including lung cancer. It has been suggested⁵⁵ that this evidence should be extrapolated to the office environment, in support of a ban on smoking in such buildings, despite the rather limited evidence, as seen in Table 2.

Surface dust and carpets are reservoirs of fungi,⁵⁶ volatile organic compounds,^{57,58} and house-dust mites,⁵⁹ which may be released when disturbed, resulting in adverse effects on health. No studies have demonstrated a reduction in symptoms after the removal of carpets, although improvement has been shown to be associated with better cleaning.^{60,61} Fungi and bacteria have been implicated in building-related illnesses because of the association of nonspecific symptoms with indicators of potential microbial contamination, such as high humidity,^{4,57,62} surface dust,^{3,10} carpets,^{3,10,43} and air conditioning.^{8,9,11,44} Microorganisms, their toxins, or both have been detected in high concentrations at sites of localized water damage,⁶³ and in heating, ventilation, and air-conditioning systems — on cooling coils,⁶⁴ filters,⁶⁵ ducts,^{66,67} humidifiers,²⁴ drip pans,⁶⁴ and air-cooling units.^{19,21,64} Nevertheless, levels of airborne microbes have been low and associated only inconsistently

with symptoms in field studies, as shown in Table 3.^{44,57,72-75}

Volatile organic compounds are produced from a wide variety of sources, including new building materials or furnishings (they account for the “new-car smell”), cleaning agents, paints, solvents, and equipment such as photocopiers.⁵⁸ In three single-blind chamber studies, controlled exposure to a mixture of volatile organic compounds commonly found in office environments resulted in mucosal irritation (Table 4).^{49,77,78} However, the concentrations of volatile organic compounds used (5000 and 25,000 µg per cubic meter) were far higher than levels detected in most field studies (Table 3),^{50,57,74,76,79} and there are no studies of controlled exposure to volatile organic compounds at the concentrations usually found in the office environment.

The controversy regarding the ventilation rate (defined as the amount of outdoor air supplied to the indoor environment) has been largely resolved by a recent synthesis.⁸⁸ The prevalence of symptoms has been found to be higher in buildings with an outdoor-air supply of less than 10 liters per second per person,^{6,7,39,41} and experimental increases in ventilation reduced symptoms (with one exception⁸⁴) if

TABLE 3. ASSOCIATION OF BUILDING-RELATED ILLNESSES WITH MEASURED ENVIRONMENTAL FACTORS.

VARIABLE (UNIT)	TYPE OF STUDY	LEVEL AT WHICH NO SYMPTOMS ASSOCIATED			LEVEL AT WHICH SYMPTOMS ASSOCIATED			
		MEAN LEVEL	RANGE	REFERENCE	MEAN LEVEL	RANGE	REFERENCE	SYMPTOM
Temperature (°C)	Field observational	23.0	22.0–24.4	57	23.0 23.3	21–26 21–26	42 68	Headache, fatigue Total no. of symptoms reported
Relative humidity (%)	Chamber	50	50–80	69	18		69	Eye, nose
		10	10–70	70				
Fungi (colony-forming units/m ³)	Field observational	9	9–50	71	>40	10–20	68	Mucosal Systemic
		32	0–111	57	97	2–978	44	Nose, throat, skin
		27	2–200	72				
		45	28–75	73				
		14	8–17	74				
Bacteria (colony-form- ing units/m ³)	Field observational	10	1–100	75	22*	10–33*	73	Total no. of symptoms reported
		574	120–2100	57				
		342	80–961	44				
Volatile organic com- pounds (µg/m ³)	Chamber	42	25–240	75	5,000 25,000		77 49, 77, 78	Mucosal Mucosal, headache, fatigue
		220	30–3930					
		70	3–740	76				
Dust (µg/m ³)	Field observational	834	100–2630	57	941	160–2353	74	Mucosal, systemic
		30	6–110	44	380	50–1380	79	Mucosal, systemic
					16	8–24	79	Eye
Formaldehyde (µg/m ³)	Field observational				22	13–29	74	Systemic
		36	12–60	74	133	10–962	80	Eye
		11	0–30	79	1,044	140–1920	81	Eye, headache, mucosal, fatigue
Carbon monoxide (ppm)	Field observational	40	0–80	57	31	11–59	76	Headache, mucosal, fatigue, skin
		4.5		50				
		3.9	2–5.5	74				

*The value refers only to gram-negative bacteria, since only gram-negative bacteria were associated with symptoms.

the base-line ventilation rates were below 10 liters per second per person but had no effect if base-line ventilation rates were higher.^{42,82,89} Hence, changes in ventilation strongly influence indoor levels of pollutants when ventilation is at low levels, but they have much less effect at higher ventilation rates.

In summary, a number of personal factors appear to be associated with nonspecific building-related illnesses, possibly because they indicate increased susceptibility. Symptoms are also associated with markers of individual exposure, such as the use of carbonless paper, photocopiers, and video-display terminals or the presence of carpets and dust, yet the specific agents responsible for the associated effects on health have not been identified. The importance of building-wide factors, such as the type or presence of mechanical ventilation^{6,8,9,11} or humidification,^{11,12} remains unclear. Studies to examine these factors were confounded by differences between buildings in the characteristics of the occupants or their work, and the results may have been biased by the occupants' awareness of the study and their atti-

tudes. Although the prevalence of symptoms has been consistently associated with temperature and humidity,^{42,68,82} this has not been the case for measured chemical and microbial levels, despite the indirect evidence implicating these factors. This lack of association may reflect the multiple agents present, their spatial and temporal variability, and the fact that current methods of measurement are expensive and insufficiently precise for the low levels usually present in office environments.

SYNTHESIS OF EVIDENCE REGARDING OFFICE-BUILDING-RELATED ILLNESSES

Nonspecific building-related illnesses may be explained by three phenomena: a wide range in the threshold of response in any population (susceptibility), a spectrum of response to any given agent, and variability in exposure within large office buildings.

Symptoms may develop in people exposed to agents at concentrations above their threshold of response. As Figure 1 shows, among healthy adults there is a wide range in the threshold for the detec-

TABLE 4. EFFECT OF EXPERIMENTAL INTERVENTIONS ON SYMPTOMS OF NONSPECIFIC BUILDING-RELATED ILLNESSES.

VARIABLES THAT COULD BE MEASURED	REDUCTION IN SYMPTOMS				NO CHANGE IN SYMPTOMS			
	REFERENCE	NO. OF SUBJECTS	BASE-LINE LEVEL	POST-INTERVENTION LEVEL	REFERENCE	NO. OF SUBJECTS	BASE-LINE LEVEL	POST-INTERVENTION LEVEL
Temperature (°C)	82	339		1.5°C lower				
Relative humidity (%)	82	339	25	40	71	8	9	50
	69	12	18	50				
	83	211	24	33				
Outdoor-air ventilation (liters/sec/person)	41	940	<7.5	25	82	339	12	24
					42	1546	14	30
					84	75	6	20
Ionization (negative ions/cm ³)	82	339	60	26,000	85	77	9500	6500

INTERVENTIONS THAT COULD NOT BE MEASURED	INTERVENTION EFFECTIVE		INTERVENTION INEFFECTIVE	
	REFERENCE	OUTCOME	REFERENCE	OUTCOME
Workstation cleaning	61	Diminished symptoms	—	—
	60	Diminished symptoms		
Cleaning of heating-ventilation-air-conditioning system	—	—	61	Symptoms unchanged
Personal control over ventilation	86	Diminished symptoms	—	—
	87	Increased productivity		
Portable air filters	—	—	82	Symptoms unchanged
			61	Symptoms unchanged

tion and irritant effects of formaldehyde^{90,91}; the same has been demonstrated for volatile organic compounds⁹² and environmental tobacco smoke.⁸⁰ Similar variability in the threshold has been demonstrated for physiologic responses to temperature^{47,48}; ozone, sulfates, and particulates⁹³; and endotoxin.⁹⁴ Although these thresholds vary markedly among individual subjects, there is much less variation in values for the same subject.⁹³ Thresholds of response are lower among workers with asthma,⁹³ those with previous building-related symptoms,⁴⁹ and those who are female^{46,48} or relatively young.^{46,48} In addition, thresholds for physiologic responses to allergens, volatile organic compounds, and environmental tobacco smoke are lowered by concomitant exposure to ozone,⁹⁵ higher temperature,⁹⁶ and lower humidity,⁶⁹ respectively.

Although initially specific building-related illnesses are identified when several workers present with similar clinical manifestations and objective abnormalities, an important but overlooked finding in outbreaks has been the wide spectrum of clinical response to the same agents.²⁰⁻²² Typically there are a few seriously affected workers with specific clinical abnormalities. Among other exposed workers, a few (often more than the number of initial sentinel cases) have mild objective abnormalities such as leuko-

cytosis or changes in lung function, whereas others have nonspecific symptoms, and some are asymptomatic yet have specific antibodies.²⁰⁻²² Without the sentinel cases, the cause of the symptoms in the other affected workers might be missed, or the outbreak might be ascribed to sick building syndrome.

Modern high-rise office buildings are designed to provide a stable and uniform indoor environment, but there is considerable temporal and spatial variation in the actual environment. Temporal variation results from changes in outdoor-air supply and outdoor air-pollution levels as well as changes in occupants and their activities.^{36,37} Spatial variation results from differences in local sources of pollutants — the occupants, their work activities, equipment, and furnishings, and materials that absorb and later re-emit contaminants⁵⁸ — and from variation in the local effectiveness of ventilation due to renovations and the normal wear and tear of the ventilation system.⁹⁷ This variability may create quite different microenvironments throughout a large building.^{75,98}

If there is independent variation in the concentration of different agents within a large office building, and in workers' susceptibility to these agents, then individual workers could be symptomatic because of localized exposure to one or more agents at levels exceeding their threshold of response. This hy-




Figure 1. Threshold for the Response to Controlled Exposure to Formaldehyde.

The figure shows the absolute threshold for the detection of the odor of formaldehyde (from Ahlstrom et al.⁹⁰), the concentration at which the odor of formaldehyde was detected in 100 percent of challenges (from Ahlstrom et al.⁹⁰), and the concentration of formaldehyde causing nasal irritation (from Horvath et al.⁹¹).

pothesis is difficult to test, because of the large number of agents and symptoms and the difficulty of accurately characterizing exposure. However, it could explain why past epidemiologic surveys failed to identify relations between environmental factors measured at a limited number of work sites and the symptoms of all workers within these buildings.^{12,57,99,100} This concept also provides the rationale for moving affected workers to another work site — a simple solution that has never been evaluated formally. Personal control over ventilation would enable workers to mitigate adverse local conditions, even if they did not know by what they were affected. This approach has been associated with reduced symptoms^{12,86} and improved productivity.⁸⁷

AN APPROACH TO THE PATIENT

Given the complexity of the indoor environment in office buildings and the numerous contributing factors, it is difficult to specify a simple, standardized approach to an office worker with a potentially work-related health problem. However, certain principles can be enunciated.

A careful history taking is an essential first step. Workers may fail to recognize the office environment as the source of their symptoms, so it is important to obtain a thorough description of the onset and course of symptoms and their temporal relation to the work environment. On the other hand, if workers attribute their symptoms to the work environment, it is still important to exclude other, non-occupational causes.

The physical examination is usually normal in nonspecific building-related illnesses, but findings may be abnormal in specific illnesses. Additional in-

vestigations may be appropriate to identify specific entities; examples are chest radiography and lung-function tests for hypersensitivity pneumonitis or asthma and skin tests and serum IgE assays for allergic manifestations.

If a building-related illness is suspected, a walk through the work site is a valuable starting point in the evaluation of the office environment. A team including the physician, industrial hygienist, and engineers is best able to identify and resolve problems in this complex indoor environment. Clinicians should familiarize themselves with public or occupational health officials at the municipal, state, or federal level who have expertise in the evaluation of similar problems. An important advantage of contacting such authorities is that they may receive reports of other affected workers in the same building. Such reports should prompt more thorough environmental assessment and may enable workers to receive compensation or similar benefits. Environmental air sampling may be indicated if specific indoor contaminants are suspected, but it is expensive and requires considerable expertise in measurement and interpretation.

Interventions demonstrated to mitigate nonspecific building-related illnesses (Table 4) should be considered, although they may not be applicable in all settings. Another possible (although untested) solution for the worker with nonspecific and unexplained symptoms would be to change his or her microenvironment by changing the work sites, even within the same building.

CONCLUSIONS

Symptoms of nonspecific building-related illnesses are common; their heterogeneity suggests that they do not represent a single disorder. Although there is little convincing, direct evidence to implicate specific causative agents, there is sufficient indirect evidence to support a number of recommendations. For example, it seems prudent to maintain an outdoor-air supply of more than 10 liters per second per person; to select the building materials, furnishings, and equipment that are least likely to release pollutants such as formaldehyde or volatile organic compounds; to ensure proper maintenance and cleaning; and to avoid materials that may act as substrates for the proliferation of microbes or dust mites.

Workers in the indoor environment of office buildings make up more than half the entire work force of industrialized countries. A substantial proportion have symptoms at work. Given the enormous population apparently affected and our current limited understanding of the health effects of this environment, further research is urgently required. Susceptibility should be assessed in experimental studies of exposure to individual and multiple pollutants at concentrations typically found in the

office environment. Proposed interventions should be evaluated in properly designed trials that incorporate standardized case definitions, questionnaires, and environmental measurement methods. Such studies could help to ensure that the man-made ecosystem within modern office buildings is a healthful work environment.

Supported by Chercheur-Boursier Clinicien awards from the Fonds de la Recherche en Santé du Québec (to Dr. Menzies) and from the Montreal Chest Institute Research Centre (to Dr. Bourbeau).

We are indebted to Drs. Margaret Becklake, Chantal Brisson, Kevin Schwartzman, and Sverre Vedal for their critical review of the manuscript and to Mme. Sylvie Ouimet for secretarial assistance.

REFERENCES

- Christie B, ed. Human factors of information technology in the office. Chichester, England: John Wiley, 1985.
- Indoor air pollutants: exposure and health effects. Copenhagen, Denmark: World Health Organization, 1983.
- Skov P, Valbjorn O, Pedersen BV, Danish Indoor Climate Study Group. Influence of personal characteristics, job-related factors and psychosocial factors on the sick building syndrome. *Scand J Work Environ Health* 1989; 15:286-95.
- Burge S, Hedge A, Wilson S, Bass JH, Robertson A. Sick building syndrome: a study of 4373 office workers. *Ann Occup Hyg* 1987;31:493-504.
- Stenberg B, Hansson Mild K, Sandstrom M, Sundell J, Wall S. A prevalence study of the sick building syndrome (SBS) and facial skin symptoms in office workers. *Indoor Air* 1993;3:71-81.
- Sundell J, Stenberg B, Lindvall T. Associations between type of ventilation and air flow rates in office buildings and the risk of SBS-symptoms among occupants. *Environ Int* 1994;20:239-51.
- Bourbeau J, Brisson C, Allaire S. Prevalence of the sick building syndrome symptoms in office workers before and after being exposed to a building with an improved ventilation system. *Occup Environ Med* 1996; 53:204-10.
- Jaakkola JJK, Miettinen P. Type of ventilation system in office buildings and sick building syndrome. *Am J Epidemiol* 1995;141:755-65.
- Mendell MJ, Fisk WJ, Deddens JA, et al. Elevated symptom prevalence associated with ventilation type in office buildings. *Epidemiology* 1996;7: 583-9.
- Wallace LA, Nelson CJ, Highsmith R, Duntzman G. Association of personal and workplace characteristics with health, comfort and odor: a survey of 3948 office workers in three buildings. *Indoor Air* 1993;3:193-205.
- Mendell MJ, Smith AH. Consistent pattern of elevated symptoms in air-conditioned office buildings: a reanalysis of epidemiologic studies. *Am J Public Health* 1990;80:1193-9.
- Zweers T, Preller L, Brunekreef B, Boleij JSM. Health and indoor climate complaints of 7043 office workers in 61 buildings in the Netherlands. *Indoor Air* 1992;2:127-36.
- Fraser DW, Tsai TR, Orenstein W, et al. Legionnaires' disease: description of an epidemic of pneumonia. *N Engl J Med* 1977;297:1189-97.
- Kaufmann AF, McDade JE, Patton CM, et al. Pontiac fever: isolation of the etiologic agent (*Legionella pneumophila*) and demonstration of its mode of transmission. *Am J Epidemiol* 1981;114:337-47.
- Dennis PJ, Taylor JA, Fitzgeorge RB, Bartlett CL, Barrow GI. *Legionella pneumophila* in water plumbing systems. *Lancet* 1982;1:949-51.
- Jaakkola JJK, Heinonen OP. Shared office space and the risk of the common cold. *Eur J Epidemiol* 1995;11:213-6.
- Brundage JF, Scott RM, Lednar WM, Smith DW, Miller RN. Building-associated risk of febrile acute respiratory diseases in Army trainees. *JAMA* 1988;259:2108-12.
- Nardell EA, Keegan J, Cheney SA, Etkind SC. Airborne infection: the theoretical limits of protection achievable by building ventilation. *Am Rev Respir Dis* 1991;144:302-6.
- Banaszak EF, Thiede WH, Fink JN. Hypersensitivity pneumonitis due to contamination of an air conditioner. *N Engl J Med* 1970;283:271-6.
- Arnoff PM, Fink JN, Schlueter DP, et al. Early detection of hypersensitivity pneumonitis in office workers. *Am J Med* 1978;64:236-42.
- Bernstein RS, Sorenson WG, Garabrant D, Reaux C, Treitman RD. Exposures to respirable, airborne *Penicillium* from a contaminated ventilation system: clinical, environmental and epidemiological aspects. *Am Ind Hyg Assoc J* 1983;44:161-9.
- Woodard ED, Friedlander B, Leshner RJ, Font WF, Kinsey R, Hearne FT. Outbreak of hypersensitivity pneumonitis in an industrial setting. *JAMA* 1988;259:1965-9.
- Hoffman RE, Wood RC, Kreiss K. Building-related asthma in Denver office workers. *Am J Public Health* 1993;83:89-93.
- Burge PS, Finnegan M, Horsfield N, et al. Occupational asthma in a factory with a contaminated humidifier. *Thorax* 1985;40:248-54.
- Tencati JR, Novey HS. Hypersensitivity angitis caused by fumes from heat-activated photocopy paper. *Ann Intern Med* 1983;98:320-2.
- Marks JG Jr, Trautlein JJ, Zwillich CW, Demers LM. Contact urticaria and airway obstruction from carbonless copy paper. *JAMA* 1984;252: 1038-40.
- LaMarte FP, Merchant JA, Casale TB. Acute systemic reactions to carbonless copy paper associated with histamine release. *JAMA* 1988;260: 242-3.
- Morgan MS, Camp JE. Upper respiratory irritation from controlled exposure to vapor from carbonless copy forms. *J Occup Med* 1986;28: 415-9.
- Verbeck S, Buise-van Unnik EM, Malten KE. Itching in office workers from glass fibres. *Contact Dermatitis* 1981;7:354.
- Farkas J. Fibreglass dermatitis in employees of a project-office in a new building. *Contact Dermatitis* 1983;9:79.
- Schneider T. Manmade mineral fibres and other fibres in the air and in settled dust. *Environ Int* 1986;12:61-5.
- Wallace LA. Carbon monoxide in air and breath of employees in an underground office. *J Air Pollut Control Assoc* 1983;33:678-82.
- Chappell SB, Parker RJ. Smoking and carbon monoxide levels in enclosed public places in New Brunswick. *Can J Public Health* 1977;68:159-61.
- Horvath SM, Dahms TE, O'Hanlon JF. Carbon monoxide and human vigilance: a deleterious effect of present urban concentration. *Arch Environ Health* 1971;23:343-7.
- Heckerling PS, Leikin JB, Maturen A, Perkins JT. Predictors of occult carbon monoxide poisoning in patients with headache and dizziness. *Ann Intern Med* 1987;107:174-6.
- Turiel I, Hollowell CD, Miksch RR, Rudy JV, Young RA. The effects of reduced ventilation on indoor air quality in an office building. *Atmos Environ* 1983;17:51-64.
- Vanderstraeten P, Muylle E, Verduyn G. Indoor air quality in a large hospital building. In: Berglund B, Lindvall T, Sundell J, eds. *Indoor air 1984*. Vol. 4. Stockholm: Swedish Council for Building Research, 1984: 335-41.
- Marbury MC, Krieger RA. Formaldehyde. In: Samet JM, Spengler JD, eds. *Indoor air pollution: a health perspective*. Baltimore: Johns Hopkins University Press, 1991:223-51.
- Jaakkola JJK, Miettinen P. Ventilation rate in office buildings and sick building syndrome. *Occup Environ Med* 1995;52:709-14.
- Stenberg B, Eriksson N, Hoog J, Sundell J, Wall S. The sick building syndrome (SBS) in office workers: a case-referent study of personal, psychosocial and building-related risk indicators. *Int J Epidemiol* 1994;23: 1190-7.
- Jaakkola JJK, Reinikainen LM, Heinonen OP, Majanen A, Seppanen O. Indoor air quality requirements for healthy office buildings: recommendations based on an epidemiologic study. *Environ Int* 1991;17:371-8.
- Menzies RI, Tamblyn R, Farant J-P, Hanley J, Nunes E, Tamblyn R. The effect of varying levels of outdoor-air supply on the symptoms of sick building syndrome. *N Engl J Med* 1993;328:821-7.
- Fisk WJ, Mendell MJ, Daisey JM, et al. Phase 1 of the California Healthy Building Study: a summary. *Indoor Air* 1993;3:246-54.
- Harrison J, Pickering CA, Faragher EB, Austwick PK, Little SA, Lawton L. An investigation of the relationship between microbial and particulate indoor air pollution and the sick building syndrome. *Respir Med* 1992; 86:225-35.
- Salvaggio JE. Recent advances in pathogenesis of allergic alveolitis. *Clin Exp Allergy* 1990;20:137-44.
- Ritchie IM, Lehnen RG. Formaldehyde-related health complaints of residents living in mobile and conventional homes. *Am J Public Health* 1987;77:323-8.
- Grivel F, Candas V. Ambient temperatures preferred by young European males and females at rest. *Ergonomics* 1991;34:365-78.
- Doeland JH, Nauta JJP, van Zandbergen JB, et al. The relationship of cold and warmth cutaneous sensation to age and gender. *Muscle Nerve* 1989;12:712-5.
- Kjaergaard SK, Molhave L, Pedersen OF. Human reactions to a mixture of indoor air volatile organic compounds. *Atmos Environ* 1991;25A: 1417-26.
- Hodgson MJ, Frohlinger J, Permar E, et al. Symptoms and microenvironmental measures in nonproblem buildings. *J Occup Med* 1991;33:527-33.
- Bauer RM, Greve KW, Besch EL, et al. The role of psychological fac-

- tors in the report of building-related symptoms in sick building syndrome. *J Consult Clin Psychol* 1992;60:213-9.
52. Karasek RA, Theorell T, Schwartz JE, Schnall PL, Pieper CF, Michela JL. Job characteristics in relation to the prevalence of myocardial infarction in the US Health Examination Survey (HES) and the Health and Nutrition Examination Survey (HANES). *Am J Public Health* 1988;78:910-8.
 53. Klitzman S, Stellman JM. The impact of the physical environment on the psychological well-being of office workers. *Soc Sci Med* 1989;29:733-42.
 54. Department of Health and Human Services. The health consequences of involuntary smoking: a report of the Surgeon General. Washington, D.C.: Government Printing Office, 1986. (DHHS publication no. (CDC) 87-8398.)
 55. Woodward A. Is passive smoking in the workplace hazardous to health? *Scand J Work Environ Health* 1991;17:293-301.
 56. Gravesen S, Larsen L, Gynstelberg F, Skov P. Demonstration of microorganisms and dust in schools and offices: an observational study of non-industrial buildings. *Allergy* 1986;41:520-5.
 57. Skov P, Valbjorn O, Pedersen BV, Danish Indoor Climate Study Group. Influence of indoor climate on the sick building syndrome in an office building. *Scand J Work Environ Health* 1990;16:363-71.
 58. Brown SK, Sim MR, Abramson MJ, Gray CN. Concentrations of volatile organic compounds in indoor air — a review. *Indoor Air* 1994;4:123-34.
 59. Wood RA, Eggleston PA, Lind P, et al. Antigenic analysis of household dust samples. *Am Rev Respir Dis* 1988;137:358-63.
 60. Leinster P, Raw G, Thomson N, Leaman A, Whitehead C. A modular longitudinal approach to the investigation of sick building syndrome. In: Walkinshaw DJ, ed. Proceedings of the Fifth International Conference on Indoor Air Quality and Climate, Toronto, July 29–August 3, 1990. Vol. 1. Toronto: Canadian Mortgage and Housing, 1990:287-93.
 61. Raw GJ, Roys MS, Whitehead C. Sick building syndrome: cleanliness is next to healthiness. *Indoor Air* 1993;3:237-45.
 62. Reinikainen LM, Jaakkola JJK, Heinonen OP. The effect of air humidification on different symptoms in office workers — an epidemiologic study. *Environ Int* 1991;17:243-50.
 63. Jarvis BB, Zhou Y, Jiang J, et al. Toxicogenic molds in water-damaged buildings: dechlorogriseofulvins from *Memnoniella echinata*. *J Nat Prod* 1996;59:553-4.
 64. Hugenholtz P, Fuerst JA. Heterotrophic bacteria in an air-handling system. *Appl Environ Microbiol* 1992;58:3914-20.
 65. Neumeister H, Moritz M, Schleibinger H, Martiny H. Investigation of allergic potential induced by fungi on air filters of HVAC systems. In: Yoshizawa S, ed. IAQ 96 — the Seventh International Conference on Indoor Climate and Air Quality. Nagoya, Japan: Organizing Committee of the Seventh International Conference on Indoor Climate and Air Quality, 1996:125-30.
 66. Smoragiewicz W, Cossette B, Boutard A, Krzystyniak K. Trichothecene mycotoxins in the dust of ventilation systems in office buildings. *Int Arch Occup Environ Health* 1993;65:113-7.
 67. Pasanen P, Pasanen AL, Jantunen M. Water condensation promotes fungal growth in ventilation ducts. *Indoor Air* 1993;3:106-12.
 68. Jaakkola JJK, Heinonen OP, Seppanen O. Sick building syndrome, sensation of dryness and thermal comfort in relation to room temperature in an office building: need for individual control of temperature. *Environ Int* 1989;15:163-8.
 69. Kay DL, Heavner DL, Nelson PR, et al. Effects of relative humidity on non-smoker response to environmental tobacco smoke. In: Walkinshaw DJ, ed. Proceedings of Fifth International Conference on Indoor Air Quality and Climate, Toronto, July 29–August 3, 1990. Vol. 1. Toronto: Canadian Mortgage and Housing, 1990:275-80.
 70. Andersen I, Lundqvist GR, Proctor DF. Human perception of humidity under four controlled conditions. *Arch Environ Health* 1973;26:22-7.
 71. Andersen I, Lundqvist GR, Jensen PL, Proctor DF. Human response to 78-hour exposure to dry air. *Arch Environ Health* 1974;29:319-24.
 72. Menzies RI, Tamblin R, Comtois P, et al. Case-control study of microenvironmental exposures to aero-allergens as a cause of respiratory symptoms — part of the sick building syndrome symptom complex. In: *Environments for people*. Atlanta: American Society of Heating Refrigerating and Air Conditioning Engineers, 1992:119-28.
 73. Teeuw KB, Vandenbroucke-Grauls CMJE, Verhoef J. Airborne gram-negative bacteria and endotoxin in sick building syndrome: a study in Dutch government office buildings. *Arch Intern Med* 1994;154:2339-45.
 74. Menzies D, Tamblin RM, Nunes F, Hanley J, Tamblin RT. Exposure to varying levels of contaminants and symptoms among workers in two office buildings. *Am J Public Health* 1996;86:1629-33.
 75. Nelson CJ, Kollander M, Clayton CA, et al. EPA's indoor air quality and work environment survey: relationships of employees' self-reported health symptoms with direct indoor air quality measurements. In: Berglund LG, ed. IAQ 1991 — healthy buildings. Atlanta: American Society of Heating Refrigerating and Air Conditioning Engineers, 1991:22-32.
 76. Sundell J, Andersson B, Andersson K, Lindvall T. Volatile organic compounds in ventilating air in buildings at different sampling points in the buildings and their relationship with the prevalence of occupant symptoms. *Indoor Air* 1993;3:82-93.
 77. Molhave L, Bach B, Pedersen OF. Human reactions to low concentrations of volatile organic compounds. *Environ Int* 1986;12:167-75.
 78. Otto D, Molhave L, Rose G, Hudnell HK, House D. Neurobehavioral and sensory irritant effects of controlled exposure to a complex mixture of volatile organic compounds. *Neurotoxicol Teratol* 1990;12:649-52.
 79. Norback D, Michel I, Widstrom J. Indoor air quality and personal factors related to the sick building syndrome. *Scand J Work Environ Health* 1990;16:121-8.
 80. Weber A. Annoyance and irritation by passive smoking. *Prev Med* 1984;13:618-25.
 81. Main DM, Hogan TJ. Health effects of low-level exposure to formaldehyde. *J Occup Med* 1983;25:896-900.
 82. Wyon DP. Sick buildings and the experimental approach. *Environ Technol* 1992;13:313-22.
 83. Reinikainen LM, Jaakkola JJK, Seppanen O. The effect of air humidification on symptoms and perception of indoor air quality in office workers: a six-period cross-over trial. *Arch Environ Health* 1992;47:8-15.
 84. Jaakkola JJK, Tuomala P, Seppanen O. Air recirculation and sick building syndrome: a blinded crossover trial. *Am J Public Health* 1994;84:422-8.
 85. Daniell W, Camp J, Horstman S. Trial of a negative ion generator device in remediating problems related to indoor air quality. *J Occup Med* 1991;33:681-7.
 86. Menzies D, Pasztor J, Nunes F, Leduc J, Chan C. Effect of a new ventilation system on health and well-being of office workers. *Arch Environ Health* 1997;52:360-7.
 87. Kroner W, Stark-Martin JA, Willemain T. Rensselaer's West Bend Mutual Study: using advanced office technology to increase productivity. Troy, N.Y.: Rensselaer Polytechnic Institute, 1994.
 88. Mendell M. Non-specific symptoms in office workers: a review and summary of the literature. *Indoor Air* 1993;3:227-36.
 89. Jaakkola JJK, Heinonen OP, Seppanen O. Mechanical ventilation in office buildings and the sick building syndrome: an experimental and epidemiological study. *Indoor Air* 1991;2:111-21.
 90. Ahlstrom R, Berglund B, Lindvall T. Formaldehyde odor and its interaction with the air of a sick building. *Environ Int* 1986;12:289-95.
 91. Horvath EP Jr, Anderson H Jr, Pierce WE, Hanrahan L, Wendlick JD. Effects of formaldehyde on the mucous membranes and lungs: a study of an industrial population. *JAMA* 1988;259:701-7.
 92. Cain W, Cometto-Muniz J. Sensory irritation potency of VOCs measured through nasal localization thresholds. In: Yoshizawa S, ed. IAQ 96 — the Seventh International Conference on Indoor Climate and Air Quality. Nagoya, Japan: Organizing Committee of the Seventh International Conference on Indoor Climate and Air Quality, 1996:167-72.
 93. Bascom R, Bromberg PA, Costa DA, et al. Health effects of outdoor air pollution. *Am J Respir Crit Care Med* 1996;153:3-50.
 94. Rylander R, Bake B, Fischer JJ, Helander IM. Pulmonary function and symptoms after inhalation of endotoxin. *Am Rev Respir Dis* 1989;140:981-6.
 95. Molfino NA, Wright SC, Katz I, et al. Effect of low concentrations of ozone on inhaled allergen responses in asthmatic subjects. *Lancet* 1991;338:199-203.
 96. Molhave L, Liu Z, Jorgensen AH, Pedersen OF, Kjaergaard SK. Sensory and physiological effects on humans of combined exposures to air temperatures and volatile organic compounds. *Indoor Air* 1993;3:155-69.
 97. Lindberg PR. Improving hospital ventilation systems for tuberculosis infection control. In: Tomasik KM, ed. Plant, technology, & safety management. Oakbrook Terrace, Ill.: Joint Commission on Accreditation of Healthcare Organizations, 1993:19-23.
 98. Hodgson MJ, Collopy P. Symptoms and the micro-environment in the sick building syndrome: a pilot study. In: IAQ '89 — the human equation: health and comfort. Atlanta: American Society of Heating Refrigerating and Air Conditioning Engineers, 1989:8-16.
 99. Burge PS, Jones P, Robertson AS. Sick building syndrome. In: Walkinshaw DJ, ed. Proceedings of the Fifth International Conference on Indoor Air Quality and Climate, Toronto, July 29–August 3, 1990. Vol. 1. Toronto: Canadian Mortgage and Housing, 1990:479-83.
 100. Robertson AS, Burge PS, Hedge A, et al. Comparison of health problems related to work and environmental measurements in two office buildings with different ventilation systems. *BMJ* 1985;291:373-6.